



**GOVT. OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D MIRZA GALIB STREET, KOLKATA- 700016**

Memo. No:- WBFES/ 3747 /2022/IND/WB/FES/20192020/78773 Dated:- 15.06.22

**From: - The Director
(Fire Prevention)
West Bengal Fire & Emergency Services**

**To: - Swati Sarawagi, Trustee
Swarnim International School
(A Unit of Swarnim Foundation)
3C, Camac Street,
Kolkata- 700016**

Subject: - Change of Name in respect of Swarnim Foundation Kolkata, an existing G+5 storied under group Educational Building situated at 180 N.S. Road, Mouza- Kodalia, J.L. No.- 35, Ward No.- 20, P.S.- Sonarpur, District- 24 Pgs. (South) under Rajpur-Sonarpur Municipality, Kolkata- 700146.

Reference: - Her Prayer Dated-13/06/2022.

Apropos above the u/s would like to convey him that this Directorate issued Fire Safety Certificate in respect of Swarnim Foundation Kolkata vide Memo. No. IND/WB/FES/20192020/78773, dated 29-04-2022 and the name rendered therein is absolutely as per the online application AIN 0125189221200068 filled in by Mr. Hari Prasad Budhia, the applicant and submitted on 11-04-2022.

However, considering the permanent N.O.C. vide No. 32-SC/AIS/NOC, Dated 19th December, 2017, issued in favour of "Swarnim International School" by the Directorate of School Education, Govt. of West Bengal, Bikash Bhawan, 7th Floor, Salt Lake, Kolkata-700091, this Directorate is accepting the prayer and accord this for change of name from "Swarnim Foundation Kolkata" to "Swarnim International School" at the same premises.

All other recommendation as mentioned in the Fire Safety Certificate issued vide Memo. No. IND/WB/FES/20192020/78773, dated 29-04-2022 shall remain in force and strictly complied with by the building authority.


Director

(Fire Prevention)

West Bengal Fire & Emergency Services



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:IND/WB/FES/20192020/78773

Date: 29-04-2022

From:
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: Swarnim Foundation Kolkata
180, N.S. Rd., Mouza-Kodalia, J.L. No.-35, Ward No.-20, P.S.-Sonarpur, Dist.-24 Pgs (S) Under Rajpur Sonarpur Municipality, Kolkata 700146

Sub: Sub: Fire Safety Certificate of an existing G+V storied under group Educational Occupancy namely Swarnim Foundation Kolkata premises at 180, N.S. Rd., Mouza-Kodalia, J.L. No.-35, Ward No.-20, P.S.-Sonarpur, Dist.-24 Pgs S Under Rajpur Sonarpur Municipality, Kolkata 700146

This is in reference to your application no. 0125189221200068 dated 11-04-2022 regarding the Sub: Fire Safety Certificate of an existing G+V storied under group Educational Occupancy namely Swarnim Foundation Kolkata premises at 180, N.S. Rd., Mouza-Kodalia, J.L. No.-35, Ward No.-20, P.S.-Sonarpur, Dist.-24 Pgs S Under Rajpur Sonarpur Municipality, Kolkata 700146

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

However, to up-keep the Fire Safety Measure of the aforesaid buildings, the following safety measures need to be incorporated / maintained:

- 1.Entrance / Exit and Driveway must be free of any type of obstruction for EASY movement of Fire Appliances. No parking will be allowed on the Drive way.
- 2.The Interior finish decoration of station building shall be made with low flame spread material confirming to the I.S. Specification.
- 3.To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the station building shall be strictly

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the "Verification of Digitally Signed Document" link and keying in the Unique Number : 0125189221200068. Page : 1

SWARNIM INTERNATIONAL SCHOOL

Swati Sarawaj
Resident Director

SWARNIM INTERNATIONAL SCHOOL

R. Biswas
Principal

For secure paperless solutions
Please visit www.emsigner.com

maintained.

4.Existing Electrical wiring of the whole station building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.

5.The notice of Fire Fighting and Evacuation from the station building shall be prepared and displayed at all vulnerable places of the building.

6.Storage area should have to be maintained proper ventilation to avoid vapour accumulation and it should be away from potential source of ignition.

7.All the vertical and horizontal ducts including all electrical ducts to be sealed by approved fire resistance materials.

8.A Fire control room including a closed circuit T.V. system shall have to be maintained which observe all floor of the station building.

9.The employees and security staff shall be conversant with installed Fire Fighting equipment of the station building and to operate in the event of Fire and Testing.

10.Mock Fire Practice and evacuation drill shall be performed periodically with participation of all the employees and security personnel of the station building.

11.Transformer, Switch Gear room and electrical panel room shall be protected with automatic Fire detection and suppression system conforming relevant I.S. Specification.

12.A crew of trained Fireman under an experienced officer shall be maintained round the clock for safety of the building.

13.First-Aid Fire Fighting system shall be maintained as per I.S. Specification.

14.Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the buildings to keep them in perfectly good working condition at all the times.

15.If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.

16.Adequate numbers of fire escape musk shall have to be maintained.

17.Direction sign of escape route shall be displayed prominently.

18.Periodical flashing of water from water based suppression system shall be made to maintain the efficient working performance of above mentioned system.

19.All the fire pumps shall always be kept in auto mode.

20.Fire Safety audit and Electrical Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189221200068. Page : 2

SWARNIM INTERNATIONAL SCHOOL

Swati Sarawaj
Resident Director

SWARNIM INTERNATIONAL SCHOOL

Powered By emSigner
R. Biswas
Principal

For secure paperless solutions
Please visit www.emsigner.com

